

# Emission Test Certificate

Friday, August 27<sup>th</sup>, 2010

Supplier: Pyrotek Noise Control (29-31 Southlink, Dandenong South, VIC, 3175)

Product Description: Soundlag

Date Tested: August 2010

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<b>SOUNDLAG</b>	<b>Total Volatile Organic Compound Specific Area Emission Rate</b> <b>mg/m<sup>2</sup>/hr</b>
24 hours	0.08
This product can be classed as low VOC-emitting. The material emissions are less than the recognised threshold of 0.5 mg/m <sup>2</sup> /hr; e.g. "Green Star".	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

CV100812